

**PLEASE DO NOT BOOKMARK ANY ANYTIMECE WEBPAGES!**

Our system will remember the last page you viewed when logging out and back in but please DO NOT exit out when taking a test. Your place will NOT be saved.



**How to take this course.**

1. Download and Print the test questions.
2. Login to your account with your ID and password.
3. Viewing your status page, scroll down and click on "[Click here to start this course](#)".



4. Begin viewing the web pages. Refer to your printed test to find the correct answers. The questions track the web pages.
5. As you find the answers, circle them on your printed copy.
6. At the end of each section, you'll enter the quiz which is the same as your printed test. Refer to your circled answers when actually answering the quiz on the web.

7. Upon passing, you will proceed to the next section. If failed to pass, you will be moved to the beginning of that section for more review.

- **Mobile users** – Many current mobile devices are compatible with AnytimeCE and will probably work. If not, use a desktop or laptop computer to complete your course.
- **WA. Electricians** – WA. L&I requires all online test questions and answers to be randomized. Be sure to answer all of the test questions on your printed copy.

**Quiz 1 Sections: WAC 296-46B-230**

Question 1: The total thickness of sheetrock required on both sides of a 2-hour firewall is \_\_\_\_\_.

- 1 inch
- 1 ¼ inch
- 2 inches
- 2 ½ inches

Question 2: Who sets the standards for the height of the center of the service meter?

- The serving utility
- The Department
- The WACs and RCWs
- The Federal Power Administration

Question 3: A service disconnect for a \_\_\_\_\_ is not required to be counted as one of

the six service disconnects allowed in NEC 230.71.

- circuit box
- transient voltage surge suppressor
- switch box
- none of the answers provided

Question 4: A residential patio cover for an overhead conductor span must have at least \_\_\_\_\_ of minimum clearance.

- 12 inches
- 24 inches
- 36 inches
- 48 inches

## WAC/RCW Part 2

RV 4.12.2014

Question 5: All overhead drops for service, feeder, or branch circuits exceeding #1 AWG aluminum or #3 AWG copper must be rigid steel galvanized conduit no smaller than \_\_\_\_\_.

- 1 inch
- 1 ¼ inch
- 2 inches
- 2 ½ inches

Question 6: All overhead drops for service, feeder or branch circuits not exceeding #1 AWG aluminum or #3 AWG copper, must be rigid steel galvanized conduit no smaller than \_\_\_\_\_.

- 1 inch
- 1 ¼ inch
- 2 inches
- 2 ½ inches

Question 7: The minimum distance between the lower loop of the entrance service wires and the roof is \_\_\_\_\_.

- 12 inches
- 16 inches
- 18 inches
- 24 inches

Question 8: \_\_\_\_\_, non-hardening mastic must be placed between lead-type flashings and the conduit.

- Aluminum
- Plastic
- Copper
- Steel

Question 9: Masts must be braced, secured, and supported in such a manner that no pressure from the attached conductors will be exerted on a roof flashing, meter base, or other enclosures. The minimum size wire for supporting is \_\_\_\_\_.

- No. 6 Copperweld
- Air craft cable
- Both of the answers provided
- Neither of the answers provided

Question 10: The minimum bracing support tubing to be used is \_\_\_\_\_.

- ½ inch rigid galvanized metal conduit
- ¾ inch rigid galvanized metal conduit
- 1 inch rigid galvanized metal conduit

Question 11: What is the minimum angle between the mast and the braces or supporting wires?

- 30 degrees
- 45 degrees
- 60 degrees

Question 12: The minimum sized U-bolts that can be used to secure the electrical mast are \_\_\_\_\_.

- ¼ inch
- 5/16 inch
- 3/8 inch
- ½ inch

Question 13: Utilization of couplings for a mast is permitted only \_\_\_\_\_ the point where the mast is braced, secured, or supported.

- above
- at
- below

Question 14: Service mast support guys must be installed if the service drop attaches to the mast more than \_\_\_\_\_ above the roofline.

- 12 inches
- 24 inches
- 32 inches
- 36 inches

Question 15: Service mast support guys must be installed if the service drop is greater than \_\_\_\_\_ in length from the pole or support.

- 50 feet
- 100 feet
- 200 feet
- 250 feet

Question 16: An Intermediate support mast must be installed in an approved manner with \_\_\_\_\_ those required for service masts.

- methods identical to
- equal to
- both of the answers provided
- neither of the answers provided

Question 17: Conductors must extend at least \_\_\_\_\_ from all mastheads to permit connection to the connecting overhead wiring.

- 12 inches
- 18 inches
- 24 inches
- 36 inches

## WAC/RCW Part 2

RV 4.12.2014

Question 18: In multi-family buildings with more than one service disconnect at different locations, a permanent identification plate must be placed at each service disconnect location and must identify \_\_\_\_\_.

- all other service disconnect locations in or on the building
- the area or units served by each disconnect
- the total number of service disconnecting means on the building
- the area or units served
- all of the answers provided

Question 19: A permanent identification plate \_\_\_\_\_ each feeder disconnecting means identifying the area.

- must be placed at
- is not required to be placed at
- must be placed only after installation at
- not adopted in the state of Washington

Question 20: If the service conductors have a lesser ampacity than the overcurrent protection or the equipment rated that they terminate in or on, an identification plate showing the ampacity of the conductors \_\_\_\_\_ on the service equipment.

- must be installed
- is not required to be installed
- only after installation is required to be installed
- not adopted in the state of Washington

Question 21: The installation of service conductors not exceeding 600 volts, nominal, within a building or structure is limited to the following methods EXCEPT \_\_\_\_\_.

- galvanized or aluminum rigid metal conduit
- galvanized intermediate metal conduit
- EMT
- rigid non-metallic conduit

Question 22: EMT (Electrical metallic tubing) must not be installed as the wiring method for service entrance conductors inside a \_\_\_\_\_.

- car
- train
- building
- park

Question 23: The grounded service conductor is permitted to be identified with a \_\_\_\_\_ or with one or more yellow strips.

- yellow jacket
- blue jacket

- green jacket
- black jacket

Question 24: Disconnects, sub-panels and similar equipment are not allowed in \_\_\_\_\_.

- bathrooms
- clothes closets
- shower rooms
- all of the answers provided

Question 25: Which is NOT required of indoor service equipment and sub-panel equipment?

- to be located with the center of the panel between 4'6" and 5' 6" from the datum plane of the floor
- to have adequate working space
- to be adequately illuminated

Question 26: Temporary construction service equipment may only be used for what purpose and when is it disconnected?

- Construction purposes
- When the permanent service is connected
- Unless the department grants an extension of time
- All of the answers provided

Question 27: A service disconnecting means located outside must be within \_\_\_\_\_ and in sight of the building served.

- 10 feet
- 15 feet
- 20 feet
- 30 feet
- 50 feet

Question 28: The building disconnecting means may supply \_\_\_\_\_ building(s).

- One
- Two
- Three

Question 29: When the service disconnecting means is installed inside the building, it must be located so that the service raceway extends no more than \_\_\_\_\_ inside the building/structure.

- 10 feet
- 15 feet
- 20 feet
- 30 feet

## WAC/RCW Part 2

RV 4.12.2014

Question 30: The installation of service conductors exceeding 600 volts, nominal, within a building or structure, must be limited to the following methods EXCEPT \_\_\_\_\_.

- galvanized rigid metal conduit
- EMT
- Schedule 80 rigid nonmetallic conduit
- metal-clad cable that is exposed for its entire length

Question 31: Grounded service conductors exceeding 600 volts nominal shall ONLY green or white in color.

- True
- False

### Quiz 2 Sections: WAC 296-46B-250 – 300

Question 1: An equipment-grounding conductor is not required to be installed with the circuit conductors between buildings.

- True
- False

Question 2: A grounded conductor (i.e., neutral) is not permitted to be used in place of a separate equipment grounding conductor between buildings.

- True
- False

Question 3: Which of the following is NOT an acceptable method for the inspector to verify that the electrode encased in concrete has been correctly installed?

- At a time previous to the electrical inspection, another inspector verified that the electrode was correctly installed.
- Accepting the job site superintendent's verbal word that the electrode was correctly installed.
- measuring the resistance of the grounding electrode attached to 20 feet of re-bar.
- All of the answers above are acceptable.

Question 4: The minimum distance apart that rods can be installed from each other in cases of services feeding adjacent but structurally separate buildings is \_\_\_\_\_.

- 2 feet
- 6 feet
- 10 feet
- 12 feet

Question 5: \_\_\_\_\_ used in nonmetallic plumbing systems are not required to be bonded

to the electrical system unless required by an electrical equipment manufacturer's instructions.

- Metallic stubs
- Valves
- Both of the answers provided
- Neither of the answers provided

Question 6: \_\_\_\_\_ are not required to be bonded together if the inspector can determine the lines are mechanically and electrically joined by one or more metallic mixing valves.

- Hot water plumbing lines
- Cold water plumbing lines
- Both of the answers provided
- Neither of the answers provided

Question 7: The neutral of a solidly grounded neutral system may be grounded at more than one point, at the following locations EXCEPT \_\_\_\_\_.

- services
- underground circuits where the neutral is exposed
- overhead circuits installed outdoors
- in new single-phase (i.e., single phase to ground) installations

Question 8: NEC power limited, Class 2, and Class 3 cables must be secured in compliance with which NEC reference article?

- NEC 334.30
- NEC 324.17
- NEC 334.34

Question 9: Generally, cables for Class 2 power limited circuits must be installed using the same methods required in Chapter 3 – Wiring Methods.

- True
- False

Question 10: Telecommunication cables must be secured in a manner that will not cause damage to the cables and at intervals not exceeding \_\_\_\_\_.

- 3 feet
- 5 feet
- 8 feet
- 12 feet

## WAC/RCW Part 2

RV 4.12.2014

Question 11: Cables are considered adequately supported when run through \_\_\_\_\_ in building structural elements or other supporting elements.

- holes
- walls
- raceways
- supporting beams

Question 12: Clamps or fittings are not required where telecommunications cables enter \_\_\_\_\_.

- rooms
- boxes
- buildings
- houses

Question 13: Optical fiber cables located in suspended ceilings must be secured in a manner that will not cause damage to the cables and at intervals not exceeding \_\_\_\_\_.

- 3 feet
- 5 feet
- 8 feet
- 10 feet
- 12 feet

Question 14: The maximum sized cable that can be supported by wires in a suspended ceiling is \_\_\_\_\_.

- ½ inch trade size
- ¾ inch trade size
- 1 inch trade size

Question 15: The maximum number of cables that can be supported by a suspended ceiling wire is \_\_\_\_\_.

- 1
- 2
- 3
- 4
- 5

Question 16: The suspended ceiling support for the two cable limitation does not apply to \_\_\_\_\_.

- 120 volt, No.14, + ground cable
- 12 gauge Romex
- Class 2 cables or Class 3 cables

Question 17: The minimum sized support wire in a suspended ceiling is \_\_\_\_\_.

- #10 AWG
- #12 AWG

- #14 AWG
- #16 AWG

Question 18: Support wires must be securely fastened to the structural ceiling and the suspended ceiling support frame.

- True
- False

Question 19: Telecommunications cables passing through ceiling area with \_\_\_\_\_ inside of ceiling area.

- no terminations
- no devices
- both of the answers provided
- neither of the answers provided

Question 20: Which of the following is NOT a requirement for cables placed in a raceway?

- That the cable is appropriate for the environment
- That the percentage fill does not exceed that allowed in NEC Chapter 9, Table 1
- That the cables are multi-stranded

### Quiz 3 Sections: WAC 296-46B-314 – 334

Question 1: In vehicular traffic areas the open bottom junction boxes must be rated for not less than \_\_\_\_\_ loading.

- None required
- H-10
- H-15
- H-20
- No open bottom junction boxes are allowed in vehicular traffic areas.

Question 2: In vehicular traffic areas the open bottom junction boxes must be provided with a bolted, hinged, or slide-on lid embossed with the identification \_\_\_\_\_.

- "JUNCTION BOX"
- "AUTHORIZED PERSONNEL ONLY"
- "ELECTRICAL"
- "NO ADMITTANCE"
- No marking required

## WAC/RCW Part 2

RV 4.12.2014

Question 3: In incidental vehicular traffic areas (e.g., parks, sports fields, sidewalks, grass lawns, etc.) the open bottom junction boxes must be rated not less than \_\_\_\_\_.

- None required
- H-10 loading
- H-15 loading
- H-20 loading
- Boxes are not rated.

Question 4: For the above application, the identification word embossed on the lid shall be \_\_\_\_\_.

- "JUNCTION BOX"
- "AUTHORIZED PERSONNEL ONLY"
- "ELECTRIC"
- "DANGER – HIGH VOLTAGE"
- None required

Question 5: In non-vehicular traffic areas (e.g., flower beds, patio decks, etc.) the open bottom junction box must be rated not less than \_\_\_\_\_.

- None required
- H-10
- H-15
- H-20
- H-30

Question 6: In non-vehicular traffic areas (e.g., flower beds, patio decks, etc.) the open bottom junction box must be designed for the purpose and must be provided with a lid embossed with the identification \_\_\_\_\_.

- "JUNCTION BOX"
- "AUTHORIZED PERSONNEL ONLY"
- "ELECTRIC"
- "DANGER – HIGH VOLTAGE"
- None required

Question 7: All conductors that are installed in approved electrical raceways (pull junction boxes) shall enter \_\_\_\_\_ into the enclosure.

- from either side
- vertically from the bottom
- from the back only
- no restrictions

Question 8: These raceways must be fitted with a \_\_\_\_\_.

- bushing
- terminal fitting
- seal
- any of the answers provided

- none of the answers provided

Question 9: The raceway shall project above the surface material not less than \_\_\_\_\_.

- 1 inch
- 2 inches
- 3 inches
- 6 inches

Question 10: The bottom surface material must be pea gravel or sand a minimum thickness of \_\_\_\_\_ or more if required by the box manufacturer.

- 1 inch
- 2 inches
- 3 inches
- 6 inches

Question 11: Placing sheet rock over a "J" box containing electrical wiring is permissible by code.

- True
- False

Question 12: "Romex" (Type NM) may be legally installed in which of the following places?

- Duplex residence
- Fourplex apartment building
- Subway Sandwich Shop
- Dental Office
- Community church building

Question 13: Romex is not allowed in a structure more than \_\_\_\_\_ floors above grade.

- One
- Two
- Three
- Four
- Five

Question 14: The first floor of a structure will be the lowest floor that has \_\_\_\_\_ or more of the exterior wall surface level with or above finished exterior grade.

- 33%
- 49%
- 50%
- 51%
- 66%

## WAC/RCW Part 2

RV 4.12.2014

### Quiz 4 Sections: WAC 296-46B-358 – 450

Question 1: EMT (electrical metallic tubing) may be installed in direct contact with the earth or in concrete on or below grade.

- True
- False

Question 2: Knob and tube wiring in an attic has been inspected and found to be in good condition. Is it legal to use loose fill insulation?

- No, remove the old knob and tube wiring and upgrade to current NEC required wires.
- No, loose filled insulation is a fire hazard.
- Yes, since the wiring does not appear to have been overheated.

Question 3: Foam insulation may be used with knob-and-tube wiring if \_\_\_\_\_.

- wiring has been inspected and authorized
- knob and tube may be allowed if modified
- not legal, never allowed to be used with knob and tube

Question 4: The following overcurrent device(s) may be used with knob & tube wiring:

- a. A penny (US 1 cent)
- b. Circuit breaker
- c. Type S fuse
- d. Inverse current fuses
- e. Choices b and c

Question 5: All luminaires within an enclosed shower area or within \_\_\_\_\_ of the waterline of a bathtub must be enclosed.

- 4 ft.
- 5 ft.
- 6 ft.
- 6 ft. 6 in.
- No exposed luminaires are permitted in a bathroom.

Question 6: The above luminaires, having exposed metal parts that are grounded, must be protected by a \_\_\_\_\_.

- Circuit breaker
- Fuse
- Inverse current fuse
- Ground fault circuit interrupter
- No special additional protection is necessary.

Question 7: A flexible cord and connection to a suspended pendant box must utilize a/an \_\_\_\_\_ threaded hub.

- Integral

- External
- Unattached
- ASME
- UPC

Question 8: The length of the cord for a suspended pendant drop from a permanently installed junction box to a suitable tension take-up device must not exceed \_\_\_\_\_.

- 4 feet
- 6 feet
- 8 feet
- 10 feet
- 12 feet

Question 9: Strain relief(s) on the flexible cord are located \_\_\_\_\_.

- on the control end
- on the equipment end
- on both ends
- not required by code

Question 10: The flexible cord must be a minimum \_\_\_\_\_ copper.

- #16 AWG
- #14 AWG
- #12 AWG
- #10 AWG
- #8 AWG

Question 11: Water heaters with a rated circuit load in excess of 3,500 watts at 208/ 240 volts, must be provided with branch circuit conductors not smaller than \_\_\_\_\_.

- #16 AWG
- #14 AWG
- #12 AWG
- #10 AWG
- #8 AWG

Question 12: All motors must be manufactured according to \_\_\_\_\_ standards for motors.

- NEMA
- ASHREA
- OSHA
- NEC
- NAACP

## WAC/RCW Part 2

RV 4.12.2014

Question 13: The minimum distance that oil-filled transformers installed outdoors may be from any portion of a building with a combustible surface is \_\_\_\_\_.

- 2 feet
- 4 feet
- 6 feet
- 8 feet
- 10 feet

Question 14: The minimum distance that oil filled transformers installed outdoors may be from any portion of a building with a non-combustible surface is \_\_\_\_\_.

- 2 feet
- 4 feet
- 8 feet
- 6 feet
- 12 feet

Question 15: In an area in which a transformer is to be installed next to an uninhabited structure, the transformer may be no closer than \_\_\_\_\_ from the building/structure.

- 2 feet
- 4 feet
- 6 feet
- 8 feet
- 10 feet

Question 16: The transformer must be outside a line \_\_\_\_\_.

- extended horizontally from the side of building
- extended vertically from the ends of the eaves or rooflines
- eyeballed and approximated

Question 17: A transformer can be installed no closer than \_\_\_\_\_ from a building's doors, windows, stairways, or other openings.

- 2 feet
- 4 feet
- 6 feet
- 8 feet
- 10 feet

Question 18: Oil leaking from the transformer should flow \_\_\_\_\_ the building.

- away from
- towards
- into a puddle next to

Question 19: The number of posts required to adequately guard a transformer is:

- 1
- 2
- 3
- 4
- No number specified

Question 20: Enclosures for total underground oil-filled transformers must not be located within \_\_\_\_\_ of a doorway.

- 4 feet
- 6 feet
- 8 feet
- 10 feet
- 12 feet

### Quiz 5 Sections: RCW 19.28.161 – 241

Question 1: Which persons are not permitted to be engaged in doing electrical trade field work?

- Master Journeyman electricians
- Electrical Administrators
- Journeyman electricians
- Apprentices with an electrical training certificate working under supervision of a journeyman
- All of the answers provided

Question 2: How often does an apprentice need to renew his/her training certificate?

- One time only
- Every 6 months
- Annually
- Every two years

Question 3: Supervision of an electrical trainee requires a journeyman at the job site.

- True
- False

Question 4: What is the maximum percentage of each working day that a journeyman does not have to be present on the job site?

- 0%
- 25%
- 33%
- 50%



## WAC/RCW Part 2

RV 4.12.2014

Question 5: A non-certified electrician may work without direct supervision during the last \_\_\_\_\_ of meeting the practical experience requirements.

- 4 months
- 6 months
- 10 months
- 12 months

Question 6: If the ratio of certified to non-certified individuals on a job site becomes one certified electrician to 3 or 4 non-certified individuals, the certified electrician must \_\_\_\_\_.

- assist the non-certified individuals by supervision, instruction and directly engaging in electrical installation
- be on the same job site with the non-certified individuals for a minimum of 75% of each working day
- accurately verify and attest to the electrical trainee hours worked by electrical trainees on behalf of the electrical contractor

Question 7: For which reason may the department review an electrical contractor's reported trainee hours?

- Excessive hours were reported.
- Hours averaged 40 per week.
- Hours were less than 40 per week.
- No over time hours were reported.

Question 8: What is the minimum number of hours you must have in fieldwork before taking the 01 Journeyman License test?

- 1000
- 2000
- 4000
- 8000

Question 9: If you successfully completed an apprenticeship program approved under chapter 49.04 RCW for the electrical construction trade, are you permitted to take the Journeyman License test?

- Yes
- No

Question 10: What is the minimum number of hours of fieldwork you must have completed before taking a specialty electrician test?

- 1000
- 2000
- 4000
- 8000

- No requirement

Question 11: How many times can a person take the competency examination?

- 1 time
- 5 times
- 11 times
- Unlimited

Question 12: How many annual hours of continuing education classes are required?

- 4
- 8
- 12
- 16

Question 13: What is the penalty for a late renewal of the certificate of competency?

- No penalty
- Twice the normal fee
- You lose your right hand.
- Start again as entry-level apprentice.

Question 14: If a holder of a temporary permit fails the exam, an extension of \_\_\_\_\_ may be issued.

- 20 days
- 30 days
- 60 days
- 90 days
- 120 days

Question 15: Which is a valid reason for the revocation of an electrical certificate?

- Misrepresenting work hours to meet field experience time to qualify to take the test.
- Scoring 100% on the exam
- Challenging an electrical inspector regarding to NEC rules and regulations
- Safe but sloppy work

Question 16: Can the department suspend the license of a person who is not in compliance with a child support order?

- Yes
- No